# A Lidar Approach to Measure CO2 Concentrations from Space for the ASCENDS Mission

James B. Abshire

Haris Riris, Randy Kawa, Graham Allan\*, Xiaoli Sun, Jeffrey Chen, Jianping Mao\*\*, William Hasselbrack\*, Clark Weaver\*\*, Anthony Yu, Mike Rodriguez

NASA Goddard Space Flight Center,
Science and Exploration Directorate, Greenbelt MD 20771 USA
\* -Sigma Space, \*\* GEST, Univ. of Maryland


Presentation to:
SPIE Remote Sensing Europe
Paper 7832-11

September 21, 2010

Supported by:

NASA ESTO IIP , Goddard IRAD, ASCENDS Definition programs

\*James.Abshire@gsfc.nasa.gov\*






## **NASA's ASCENDS Mission**



Active Sensing of CO<sub>2</sub> Emissions over Nights, Days, and Seasons (ASCENDS)

Active Sensing of CO<sub>2</sub> Emissions over Nights, Days, and Seasons (ASCENDS) Launch: 2013-2016





Inventory of global CO, sources and sinks



Connection between climate and CO2 exchange



Improved climate models and predictions of atmospheric CO2



Identification of human-generated CO<sub>2</sub> sources and sinks to enable effective carbon trading



Closes the carbon budget for improved policy and prediction

#### Why lidar?

- · Measures at night & all times of day
- Measurements at high latitudes & continuous over oceans
- Constant nadir/zenith path
  - Illumination = observation path
- Measure through broken clouds & to cloud tops
- Very high spectral resolution and accuracy



Active Sensing of CO<sub>2</sub> Emissions over Nights, Days, and Seasons (ASCENDS) Mission

**NASA Science Definition and Planning Workshop Report** 

July 23-25, 2008 University of Michigan in Ann Arbor, Michigan

For more information, see 2008 Workshop report: http://cce.nasa.gov/ascends/index.htm



# **Laser Sounder Approach for ASCENDS Mission**



#### Simultaneous laser measurements:

- 1. CO2 lower tropospheric column One line near 1572 nm
- 2. O2 total column (surface pressure) Measure 2 lines near 765 nm Altimetry & atmospheric backscatter profile from CO2 signal:

## Measures: ~450 km polar orbit - CO2 tropospheric column - O2 tropospheric column CO2: 1572 nm - Cloud backscattering profile 02: 765 nm clouds larget: ~ 1ppmV in ~100 km along track sample Need ~0.2% measurements of CO2 & O2 columns in ~10 sec

#### Measurements use:

- Pulsed lasers
- ~10 KHZ pulse rates
- · 8 laser wavelengths for CO2 line
- •Time resolved Photon counting receiver

#### CO2 & O2 column measurements:


- · Pulsed signal approach :
  - · Isolate full column signal from surface
  - Reduces noise from detector & solar background
  - Time of flight provides column length





# CO2 Band, Line Sampling & Vertical Weighting Functions





Total Column from area of line

Wovelength (nm) 1572.4 1572.3 1572.5 1572.2 1572.1 0.8 Transmittance 3 Column density from line extinctions: Increasing 0.2 E3/E1, and CO2 Column E4/E1 Density 6360.0 Wave Number (cm-1) Space lidar: 8 wavelength samples across

#### Multi-wavelength Line Sampling allows:

- Detection & correction of Doppler &  $\lambda$  errors
- Modeling & reducing errors from varying  $\lambda$  response
- CO2 retrievals for lower & upper troposphere
- Line shape information





line




## 1572.33 nm line is well suited for measurement











✓ Greater sensitivity to atmospheric CO2 amount



# Why use pulsed lasers & range resolution? Atmospheric Scattering

- Thin cirrus clouds are quite prevalent,  $\beta_{\pi}$  varies with  $\lambda$
- Cloud reflections shorten average optical path -> bias non-gated column estimates
- Cirrus cloud scattering -> 4-10 ppm errors in non-range gated measurements
- Pulsed lasers & range gating eliminate these errors






# Pulsed Airborne CO2 Sounder Lidar on the NASA Glenn Lear-25



Experiment Team in Ponca City OK, USA

Nadir port showing transmit and receiver windows







#### Flights on Lear 25:

Oct & Dec 2008

July & August 2009





SPIE Paper 7832-11:
Pulsed Lidar to Measure CO2 Concentrations for the ASCENDS Mission



#### **Pulsed Airborne CO2 Lidar**







#### 2009 Parameters:

Laser peak power: 24 watts (24 uJ/pulse) Laser divergence angle: 100 urad

Laser: DFB diode laser, AOM, Fiber amplifier CO2 line: 1572.33 nm

Wavelength scans: 20 wavelengths, 450 Hz Receiver FOV: 200 urad

Telescope diameter: 20 cm Receiver optical bandwidth: 0.8 nm

Receiver transmission: 65%\* Detector quantum efficiency: 2 %

PMT dark count rate: ~ 550 kHz Receiver range bin size: 8 nsec









(LaRC/ITT Lidar, LaRC in-situ)

4. UC-12

Coordinated Airborne Experiments to Measure CO2 column densities to support ASCENDS Science Mission Definition (August 2009)






# Examples of Measurements through 2 Cloud layers (cloud, cloud, ground echo pulses)




Nadir Camera Image for Measurement



Expanded view of 1st echo pulse group in sequence






Ranges & scattering Profiles from times of Flight of pulses Absorption line shapes: to clouds - thinner, less deep to ground - broader & deeper







# Examples of Line shapes vs Altitude North Carolina Flight - August 17, 2009















- Depth increases with altitude
- · Smooth line shapes at all altitudes!











INDS IMISSIOII




# Line Optical Density & # Density vs Altitude North Carolina Flight - August 17, 2009







• 4 papers on 2009 CO2 & O2 measurements at 25th ILRC conference, St. Petersburg, Russia, July 2010.




- Mean Optical Depths from line fits to CO2 Sounder measurements
- # Densities calculated from LaRC in-situ sensor and radiosonde readings





# Airborne Experiments to Measure CO<sub>2</sub> Column Densities to Support ASCENDS Mission Definition; July 5-18, 2010





- Multi-functional Fiber Laser Lidar (MFLL)
- Ed Browell/LaRC, Team Leader
- Instrument development via ITT IRAD, NASA AITT funding, LaRC IRAD
- CO<sub>2</sub> Sounder lidar with O<sub>2</sub> measurement experiment
- Jim Abshire/GSFC, Team Leader
- Instrument development via NASA ACT & IIP programs, GSFC IRAD
- CO<sub>2</sub> laser absorption spectrometer (CO<sub>2</sub>LAS)
- Gary Spiers/JPL, Team Leader
- Instrument development via NASA ACT, IIP & AITT programs, JPL IRAD


ENDS MISSION



# CO2 Sounder: July 2010, NASA DC-8 configuration




















### O2 absorption measurements from laboratory











#### Airborne O2 Lidar Parameters:

- Diode laser Wavelength: 1529 nm
- Amplifier: NP Photonics EDFA
- Output Wavelength: 764.5 nm
- Output Energy: ~2 uJ/pulse
- Detector: Si APD SPCM
- Scan over the absorption with 40 Pulses (selectable) at 250 Hz

#### Distance to target: 1.5 km Target illuminated by green alignment laser






Calculated





# Initial Airborne lidar Measurements of O2 line & column absorption Calculated O2 line shape vs altitude





Bill Hasselbrack & Mike Rodriguez at CO2 (left) & O2 lidar (right) controls on NASA DC-8 during July 2010






SPIE Paper 7
Pulsed Lidar to Measure CO2 Concent



# Airborne lidar Measurement of O2 line column absorption made on July 14, 2010 over Pacific Ocean







100-

1st measurements, Initial look at data, Little processing, Not yet calibrated

50-


• Laser energy ~2 uJ/pulse, Ave laser power ~10 mW, 20 sec averaging




# **Summary of 2 Space Lidar Studies**



- Conducted studies of this approach for ASCENDS space lidar: 4/08 & 9/09
- Straightforward space lidar design:
  - Mass: ~ 400 Kg
  - Power: ~ 850W (with 3dB margin); driven by SNR needs
  - Data rate: ~1.9 Mbit/sec
- Low risk: Space qualified telescope, O2 detectors
- Detectors: reliability via multiple detectors & spares.
- Primary power draw: lasers
- Lasers: high efficiency & reliability
- Mission compatible with medium class rocket
   (Taurus-II or equivalent), with considerable margin
- Can be further optimized in future studies










## **Space: SNR & Relative Measurement Errors**




(10 seconds observing time, 500\* km orbit, 1.5m telescope)


#### CO2 column measurement

#### O2 column measurement



#### Oxygen Measurement Performance from Space





~ 3 mJ/pulse energy (HgCdTe detector\*) ~ 3 mJ/pulse energy (SPCM detector)

Ave optical power ~25-30W

6 mJ energy from 1530 nm amp, 50% doubling

Ave optical power ~25-30 W

\* - Same performance at 3 mJ/pulse with PMTs at 400 km orbit






## Laser Power Scaling to 3-6 mJ/pulse

#### 1. High SBS-threshold Er/Yb co-doped phosphate glass fiber amplifier


- High SBS-threshold, SM, PM, high power amplifiers using NP Photonics large core SINGLE-MODE PM highly Er/Yb codoped phosphate fibers
- Develop amplifier prototypes/products:  $50\mu J$ ,  $100s~\mu J$  and mJ.
- · Push the SBS threshold to 100s kW.



SBIR (-1 & -2) with NP Photonics (Wei Shi,PI)

Near-term Raytheon applications of fiber lasers have been in various versions of laser sensors, including a state-of-the-art coherent laser radar system. In the commercial world, fiber lasers are becoming the laser of choice in a number of laser processing applications, most significantly in the marking area where they essentially dominate all other options.

Planar Waveguide Lasers (PWGs), are high aspect ratio sandwich-type structures consisting of a high-index active core surrounded by lower index claddings. A PWG is essentially a one-dimensional fiber in which the thin transverse axis is guided and the wide transverse axis is unguided. The core, typically 5 to 200  $\mu$ m thick, may be single-mode or multimode and may be




#### **Raytheon**

Customer Success Is Our Mission

# 2. Amplifier R&D Planar Waveguide Amplifiers

Planar waveguides allow guided mode amplification with much larger areas => higher peak powers & energies





# Summary



#### CO2 Sounder approach for ASCENDS:

- CO2 and O2 measurements:
  - Line shape & column heights
  - 2 altitude weighting functions
  - Pulsed lasers & multi–λ samples:
     Robust against instrument errors
     & atmospheric scattering
- Airborne column measurements:

CO2 in 2008, 2009, 2010 O2 (1st time) in 2010

- Laser components needed are practical
- 1st Mission simulations show meets science needs, more are being carried out
- ASCENDS launch scheduled for 2019

More Information (papers in *Tellus-B*) ->

Tellus SERIES B CHEMICAL AND PHYSICA METEOROLO

Tellus (2010)

Printed in Singapore. All rights reserved

Journal compilation © 2010 Blackwell Munksgaard No claim to original US government works

TELLUS

#### Simulation studies for a space-based CO<sub>2</sub> lidar mission

By S. R. KAWA<sup>1\*</sup>, J. MAO<sup>2</sup>, J. B. ABSHIRE<sup>1</sup>, G. J. COLLATZ<sup>1</sup>, X. SUN<sup>1</sup> and C. J. WEAVER<sup>2</sup>,

<sup>1</sup>NASA Goddard Space Flight Center, Greenbelt, MD, USA; <sup>2</sup>Goddard Earth Sciences and Technology Center,

University of Maryland Baltimore County, Baltimore, MD, USA

(Manuscript received 22 December 2009; in final form 25 June 2010)

#### ABSTRACT

We report results of initial space mission simulation studies for a laser-based, atmospheric CO<sub>2</sub> sounder, which are based on real-time carbon cycle process modelling and data analysis. The mission concept corresponds to the Active Sensing of CO<sub>2</sub> Emissions over Nights, Days and Seasons (ASCENDS) recommended by the US National Academy of Sciences' Decadal Survey. As a pre-requisite for meaningful quantitative evaluation, we employ a CO<sub>2</sub> model that has representative spatial and temporal gradients across a wide range of scales. In addition, a relatively complete description of the atmospheric and surface state is obtained from meteorological data assimilation and satellite measurements. We use radiative transfer calculations, an instrument model with representative errors and a simple retrieval approach to quantify errors in 'measured' CO<sub>2</sub> distributions, which are a function of mission and instrument design specifications along with the atmospheric/surface state. Uncertainty estimates based on the current instrument design point indicate that a CO<sub>2</sub> laser sounder can provide data consistent with ASCENDS requirements and will significantly enhance or ability to address carbon cycle science questions. Test of a dawn/dusk orbit deployment, however, shows that diurnal

Tellus (2010)
Printed in Singapore. All rights reserved

Tellus B © 2010 International Meteorological Institute in Stockholm No claim to original US government works

TELLUS

# Pulsed airborne lidar measurements of atmospheric CO<sub>2</sub> column absorption

By JAMES B. ABSHIRE<sup>1\*</sup>, HARIS RIRIS<sup>1</sup>, GRAHAM R. ALLAN<sup>2</sup>, CLARK J. WEAVER<sup>3</sup>, JIANPING MAO<sup>3</sup>, XIAOLI SUN<sup>1</sup>, WILLIAM E. HASSELBRACK<sup>2</sup>, S. RANDOPH KAWA<sup>1</sup> and SEBASTIEN BIRAUD<sup>4</sup>, <sup>1</sup>NASA Goddard Space Flight Center, Greenbelt, MD 20771, USA; <sup>2</sup>Sigma Space Inc., Lanham, MD 20706, USA; <sup>3</sup>Goddard Earth Sciences and Technology Center, University of Maryland Baltimore County, Baltimore, MD 21228, USA; <sup>4</sup>Lawrence Berkeley National Laboratory, Berkeley, CA 94720, USA

(Manuscript received 29 December 2009; in final form 22 July2010)

#### ABSTRACT

We report initial measurements of atmospheric CO<sub>2</sub> column density using a pulsed airborne lidar operating at 1572 nm. It uses a lidar measurement technique being developed at NASA Goddard Space Flight Center as a candidate for the CO<sub>2</sub> measurement in the Active Sensing of CO<sub>2</sub> Emissions over Nights, Days and Seasons (ASCENDS) space mission. The pulsed multiple-wavelength lidar approach offers several new capabilities with respect to passive spectrometer and other lidar techniques for high-precision CO<sub>2</sub> column density measurements. We developed an airborne lidar using a fibre laser transmitter and photon counting detector, and conducted initial measurements of the CO<sub>2</sub> column absorption during flights over Oklahoma in December 2008. The results show clear CO<sub>2</sub> line shape and absorption signals. These follow the expected changes with aircraft altitude from 1.5 to 7.1 km, and are in good agreement with column number density estimates calculated from nearly coincident airborne in-situ measurements.